

ລັດວິສາຫະກິດຖືຮຸ້ນລາວ
 ຖະໜົນລ້ານຊ້າງ, ບ້ານຫັດສະດີ
 ເມືອງຈັນທະບູລີ, ຕູ້ໂປສະນີ 11536
 ນະຄອນຫຼວງວຽງຈັນ, ສປປ ລາວ
 ໂທ: (856-21) 263805, 263806
 ແຟັກ: (856-21) 263804



ທົງສາ, ວັນທີ 12 ຕຸລາ 2017

ຕາຕະລາງລາຍງານຜົນວິໄຈຄຸນນະພາບຂີ້ເທົ່າລອຍປະຈຳອາທິດ

No	Sample	Unit	Sampling Date and Time		%CaO Freelime	%SO ₃	%Loss on ignition	%Moisture	%Chemical											% (SiO ₂ +Fe ₂ O ₃ +Al ₂ O ₃)
									Na ₂ O	MgO	Al ₂ O ₃	SiO ₂	Fe ₂ O ₃	P ₄ O ₁₀	K ₂ O	CaO	TiO ₂	MnO ₂	SO ₃	
1	FA1-051017-H	1	05-10-17	0:00	0.48	0.27	0.60	0.10	0.85	0.54	31.88	44.74	5.60	0.05	2.61	6.00	0.43	0.03	0.28	82.22
2	FA2-051017-H	2	05-10-17	0:00	0.52	0.29	0.49	0.10	0.90	0.41	31.82	43.83	5.49	0.05	2.53	5.90	0.40	0.03	0.33	81.14
3	FA1-061017-H	1	06-10-17	0:00	0.51	0.28	0.48	0.09	0.90	0.37	31.82	43.92	5.30	0.05	2.55	5.81	0.40	0.03	0.32	81.04
4	FA2-061017-H	2	06-10-17	0:00	0.47	0.26	0.47	0.10	0.88	0.49	31.84	44.28	5.58	0.05	2.57	5.91	0.41	0.03	0.32	81.70
5	FA1-071017-H	1	07-10-17	0:00	0.46	0.29	0.57	0.05	0.85	0.51	31.86	44.44	5.73	0.05	2.58	5.91	0.41	0.03	0.29	82.03
6	FA2-071017-H	2	07-10-17	0:00	0.46	0.30	0.47	0.05	0.92	0.36	29.08	40.67	4.86	0.05	2.15	5.71	0.35	0.03	0.35	74.61
7	FA1-091017-H	1	09-10-17	0:00	0.47	0.29	0.45	0.08	0.86	0.48	31.86	44.53	5.60	0.05	2.58	5.90	0.43	0.03	0.30	81.99
8	FA2-091017-H	2	09-10-17	0:00	0.48	0.24	0.53	0.07	0.86	0.57	31.86	44.51	5.91	0.05	2.60	6.00	0.43	0.04	0.30	82.29
9	FA1-101017-H	1	10-10-17	0:00	0.51	0.21	0.55	0.05	0.91	0.34	29.57	40.89	4.91	0.05	2.26	5.76	0.35	0.03	0.34	75.37
10	FA2-101017-H	2	10-10-17	0:00	0.53	0.19	0.45	0.04	0.85	0.56	31.88	44.70	6.06	0.05	2.62	6.05	0.42	0.04	0.29	82.64
11	FA1-111017-H	1	11-10-17	0:00	0.49	0.19	0.45	0.03	0.85	0.56	31.87	44.70	5.61	0.05	2.59	5.88	0.42	0.03	0.30	82.17
12	FA2-111017-H	2	11-10-17	0:00	0.45	0.19	0.33	0.04	0.86	0.52	31.85	44.39	5.55	0.05	2.57	5.88	0.41	0.03	0.29	81.79
Maximum					0.53	0.30		0.10	0.92	0.57	31.88	44.74	6.06	0.05	2.62	6.05	0.43	0.04	0.35	82.64
Minimum					0.45	0.19	0.33	0.03	0.85	0.34	29.08	40.67	4.86	0.05	2.15	5.71	0.35	0.03	0.28	74.61
Average					0.49	0.25	0.49	0.07	0.9	0.48	31.43	43.80	5.52	0.05	2.52	5.89	0.40	0.03	0.31	80.75
Std.Dev					0.03	0.04	0.07	0.03	0.03	0.08	0.99	1.44	0.35	0.00	0.15	0.10	0.03	0.00	0.02	2.73

5. ຫົວໜ້າພະແນກທຸລະກິດຂີ້ເທົ່າລອຍ

ສິດທິເດດ ສຸຂະທຳມະວົງ

ຜູ້ລາຍງານ

 ໄກທອງ ວັນທະພິມ